

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 14/02/2025

It is certified that an inspection team headed by Naveen Kumar Das, Chemist(Name of Officers with designation) from District water testing Laboratory P.H.E.D Surajpur(Name of Department/ Office) inspected the Global Public School, Surajpur, Bhayathan road(Name & Address of the school) on 14.02.2025 (date of inspection) and found that the Global Public School, Surajpur (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.The above is valid for a period of 1 year

Signature with Seal:

District Water Testing Laboratory
P.H.E.D. Surajpur (C.G.)

Name

Naveen Kumar Das

Designation

ChemistName & Address of the Office / Department : P.H.E.DSurajpur

To

Global Public School, SurajpurBhayathan road, Surajpur

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

DISTRICT WATER TESTING LABORATORY (National Drinking Water Mission)

Public Health Engineering Department, Division-Surajpur, Ketka road, Surajpur Distt-Surajpur (C.G.)

District- Surajpur Samples

- (i) Date of Collection- 13.02.2025
- (ii) Date of Received- 13.02.2025
- (iii) Date of Analysis - 14.02.2025

Details of Source & Location-

Global Public School Surajpur
Block- Surajpur, District-Surajpur (C.G.)
Pin Code - 497229
(i) Water sample- Borewell water sample

No of Sample-01

Ref. क्रमांक/ 2025 दिनांक:-


Note-Water sample brought by School staff.

S No	Characteristics	Unit Table	Acceptable	Cause of rejection	Results					
					(i)	(ii)	(iii)	(iv)	(v)	
PHYSICAL										
1	Turbidity	N.T.U	1.0	5.0	10.00					
2	Colour	Pt Cobalt Scale	5.0	15	2.00					
3	Taste		Unobjectionable	objectionable	Agr.					
4	Odour		Unobjectionable	objectionable	Agr.					
Chemical										
5	pH	pH Scale	6.5 to 8.5	<6.5 or >8.5	6.569					
6	Total Alkalinity	mg/l	200	600	29.805					
7	Chlorides	mg/l	250	1000	26.703					
8	Nitrates	mg/l	45	45	5.00					
9	Total Hardness (as CaCO ₃)	mg/l	200	600	64.29					
10	Calcium (as ca)	mg/l	75	200	21.61					
11	Magnesium (as Mg)	mg/l	30	100	2.48					
12	Iron	mg/l	0.1	1.0	0.00					
13	Fluorides	mg/l	1.0	1.5	0.016					
14	Total dissolved Solids	mg/l	500	2000	180.00					
15	Residual Chlorine	mg/l	0.2	1.0	0.00					
BACTERIOLOGICAL-										
16	Coli form organisms At 37° C	M.P.N/ 100ml	24 Hrs		-ve					
			48 Hrs		-ve					

REMARK -

5	pH	pH Scale	6.5							
6	Total Alkalinity	mg/l	200							
7	Chlorides	mg/l	250							
8	Nitrates	mg/l	45							
9	Total Hardness (as CaCO ₃)	mg/l	200							
10	Calcium (as ca)	mg/l	75							
11	Magnesium (as Mg)	mg/l	30							
12	Iron	mg/l	0.1							
13	Fluorides	mg/l	1.0							
14	Total dissolved Solids	mg/l	500							
15	Residual Chlorine	mg/l	0.2							

-----End of Report-----


 In charge/Chemist
 Water Testing Laboratory
 P.H.E. Sub-Division
 Surajpur, District-Surajpur (C.G.)
PHED (C.G.)